



कार्यालय,
अधिशायी अभियन्ता,
खण्ड कार्यालय, उ०प्र० जल निगम(ग्रामीण),
महाराजगंज

पत्रांक: 1945 / विविध-35 / 132

दिनांक: 25/08/2026

सेवा में,

प्रधानाचार्य,
St. Joseph's School
निचलौल,
जनपद-महाराजगंज।

विषय:- पानी की शुद्धता की जाँच रिपोर्ट के सन्दर्भ में।

महोदय,

उपरोक्त विषयक आपके द्वारा दिनांक 11.08.2026 को 1 नग जल नमूनों का सैम्पल गुणवत्ता परीक्षण हेतु उपलब्ध कराये गये हैं। उक्त जल नमूनों का परीक्षण इस खण्ड के विभागीय प्रयोगशाला में किया गया, जिसका परीक्षण रिपोर्ट पत्र के साथ संलग्नकर प्रेषित है।

संलग्नक- जल परीक्षण रिपोर्ट।

भवदीय

अधिशायी अभियन्ता

पुं०सं० एवं दिनांक तदैव:-

प्रतिलिपि: निम्नलिखित को सूचनार्थ प्रेषित।

1. सहायक अभियन्ता/जू०इं० (प्रयोगशाला)।

अधिशायी अभियन्ता



**District Level Water Analysis Laboratory,
U.P. Jal Nigam(Rural), Maharajanj
Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
District-Maharajanj-273303**



TC-16954

Analysis Report

URL No. TC-16954/26/0000000802F

Date 14.08.2026

Page No. 1/2

Customer Name - Principal

Address - St. Joseph's School, Nichloul, District- Maharajanj.

Reference Letter No. - N/A

Basic Details of sample**District- Maharajanj**

Gram Panchayat/ Nagar	Nichloul	Village/Nagar	Nichloul
		Latitude	27.326737
		Longitude	83.737574
Habitation	Nichloul	Location	St. Joseph's School, Nichloul, District- Maharajanj.
Water Source	R.O.	Date of S.C.	11.08.2026
Quantity of Sample	1500ml	Sample Collector	By Sampler
Receiving Date	11.08.2026	Analysis Completion Date-	14.08.2026
Sample Receive	Sampler		
Analysis Start Date	11.08.2026		
Temperature - 25 +C		Relative Humidity - 50+-15%	

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Turbidity	1.68	NTU	1.00	5.00	IS 3025 (Part 10) : 2023
2	TDS	80.00	mg/L	500.00	2000.00	IS 3025 (Part 16) : 2023
3	pH	7.37	-	6.5 - 8.5	No relaxation	IS 3025 (Part 11) : 2022
4	Total Hardness	70.00	mg/L	200.00	600.00	IS 3025 (Part 21) : 2019
5	Total Alkalinity	106.00	mg/L	200.00	600.00	IS 3025 (Part 23) : 2023
6	Chloride as Cl	22.00	mg/L	250.00	1000.00	IS 3025 (Part 32) : 2019
7	Calcium	19.58	mg/L	75.00	200.00	IS 3025 (Part 40) : 2019
8	Magnesium	6.24	mg/L	30.00	100.00	IS 3025 (Part 46) : 2019
9	Colour	10.00	Hazen	5.00	15.00	IS 3025 (Part 4) : 2021
10	Sulphate	24.14	mg/L	200.00	400.00	APHA24rd Edition-4500-SO4 Method E (Turbidimetric Method)
11	Nitrate	1.71	mg/L	45.00	No relaxation	APHA24rd Edition-4500-NO3 Method B (UV Screening Method)
12	Iron	0.000	mg/L	1.00	No relaxation	APHA24rd Edition-4500-Fe Method B (Phenanthroline- Method)
13	Arsenic	0.00	mg/L	0.01	No relaxation	APHA24rd Edition-4500-As Method B (Silverdiethyldithiocarbamate- Method)
14	Fluoride	0.000	mg/L	1.00	1.50	APHA24rd Edition-4500-F Method C (Electrode Method)

Note:-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

Prepared By

Anand Agudhauri
Review By

(Radheyshyam Rawat)

Quality Manager

Authorized Signatory

Mob.No. 8858396541

Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report





**District Level Water Analysis Laboratory,
U.P. Jal Nigam(Rural), Maharajganj**
Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
District-Maharajganj-273303

Date 14.08.2026

Page No. 1/2

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Conductivity	160.00	mS/cm	NA	NA	IS 3025 (Part 14)
2	E-Coli (Bacteria)	0.00	CFU	Nil	Nil	IS 15181:2016

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

[Signature]
Prepared By

[Signature]
Review By

[Signature]
(Radheyshyam Rawat)
Quality Manager

Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report

Authorized Signatory

Mob.No: 8858396541

Manager

UPIN-MRJ

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Date .08.2026

It is certified that an inspection team headed by EXECUTIVE ENGINEER from DIVISION OFFICE U.P JAL NIGAM (RURAL) DISTRICT-MAHARAJGANJ inspected the **St. Joseph's School, Nichlaul, District-Maharajganj.** (Name & Address of the School) on 12.08.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing URL No. TC-16954/26/0000000802F Dated 14.08.2026 of District Level Water Analysis Laboratory (NABL Lab) Certificate that the **St. Joseph's School,** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

The certificate is valid till 14.08.2026 to 14.02.2027


Executive Engineer
Division Office
U.P. Jal Nigar (Rural)
District-Maharajganj

To,

St. Joseph's School,
Nichlaul,
District- Maharajganj.

Note-The Certificate is to be issued by authorized officer / NABL Lab/Local bodies